

No. 8-387/89-FC
Government of India
Ministry of Environment & Forests
Deptt. of Environment, Forests & Wildlife

Paryavaran Bhavan, CGO Complex,
Lodi Road, New Delhi-110003.

Dated the December 12, 1989.

To

The Secretary
Forest Department
Government of Madhya Pradesh
Bhopal.


Subject: Diversion of 3.325 ha. of forest land in Davas distt. for the construction of 11 KV transmission line to M.P. Electricity Board.

Sir,

I am directed to refer to your letter No. F-5/39/89/10/3 dated 7.8.89 on the above mentioned subject seeking prior approval of the Central Government in accordance with Section-2 of the Forest(Conservation) Act, 1980.

2. After careful consideration of the proposal of the State Government, the Central Government hereby conveys its approval under Section-2 of the Forest (Conservation) Act, 1980 for diversion of 3.325 ha. of forest land in Davas distt. for the construction of 11KV trans. line to M.P. Electricity Board subject to following conditions :-

1. Only temporary use of forest land would be permitted for laying the proposed trans. line and the legal status of the land will remain unchanged.
2. The maximum width of right-of-way for the transmission line on the forest land shall be 7M.
3. Tree growth existing within the right-of-way would be permitted to be felled but after the stringing work is completed, dwarf trees would be planted keeping in view the electric clearance to be maintained except in the outer 3 M wide strip which shall be left clear to permit maintenance of the transmission line.
4. Removal of tree growth existing within the right-of-way would be permitted over 3 M wide strips below each conductor for taking the tension stringing equipment. The trees on such strips would be permitted to be felled but after the stringing work is complete dwarf trees would be planted keeping in view the electric clearance to be maintained, except in one outer strip which shall be left clear to permit maintenance of the transmission line. In the remaining width within the right-of-way trees will not be felled but may be lopped to the extent



h. sharma
Azad
Dunlop
L.M.
Adv. Ct. (1989)

श्री. मुख्य वन सचिव
मध्य प्रदेश भोपाल
90/1

required to maintain minimum clearance of 5.5 M from the conductors.

Yours faithfully,



(M.K. JIWARAJKA)

Asstt. Inspector General of Forests.

Copy to :-

- ✓ 1. Chief Conservator of Forests, Govt. of Madhya Pradesh, Bhopal
2. Regional Office(Western Zone), E-3/240, Arera Colony, Bhopal(MP).
3. Regional Office(HQ), New Delhi.
4. Gaurd file.



(M.K. JIWARAJKA)

Asstt. Inspector General of Forests.